

Industrial, Commercial & Domestic

PORTABLE APPLIANCE TEST CERTIFICATE Certificate Number gegown Job Number Tester's Name Tester's Date of Date of G Deakin 3/4/12 3/4/13 Signature Test Next Test (caps) GEG Mainteance Services Ltd Site Address if Customer Name N/A 37 Kempson Avenuue different to Client and Address Birmingham B72 1HL Address Test Equipment Type and Serial No power tools Visual Instrument Tests Class of Appliance Inspection Condition Overall Ref Description of Location of of Comments / Details of Remedial Work Result Appliance Appliance No Plug-Earth Flexible Insulation of Test Cord & Fuse Continuity Resistance Grips-Size test (Ω) $(M\Omega)$ correct polarity 80 dewalt drill 18v stores **Pass** 13A 2 8.0 >299 Pass good order Pass Pass 09 dewalt drill 24v stores 13A 2 0.11 >299 good order 11 dewalt drill stores pass 13A 2 0.17 >299 Pass replaced plug top 12 transformer 1 stores Pass 13A 2 0.22 >299 Pass goodorder 13 transformer 2 stores Pass 13A 2 0.21 >299 Pass reflexed 15 dealt drill 18v 2 stores Pass 13 2 0.9 >299 Pass good order 4 inch grinder 13A 2 0.14 >299 Pass 16 stores pass good order 17 9 inch grinder stores Fail 13A 2 0.18 >299 Fail new blade gaurd on order bosh drill 24v Pass 13A 2 0.16 >299 Pass 18 stores good order 19 tile cutter Fail 13A 2 0.27 >299 Fail no blade cover stores 21 solder iron Pass 13A 2 0.11 >299 Pass good order stores 23 dewalt drill 18v 4 Pass 13A 2 0.16 >299 Pass good order stores Page of